



## SUGGESTED SPECIFICATIONS

### BELOW GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301 "", ASTM A888<sup>01</sup> or ASTM A74<sup>01</sup>. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

### ABOVE GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301 "", ASTM A888<sup>01</sup> or ASTM A74<sup>01</sup>. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

### JOINTS

- No-Hub Couplings shall conform to the CISPI 310" Standard and ASTM A1277 and be listed by NSF International.
- Heavy-Duty Couplings shall conform to the requirements of ASTM C1540.
- Compression Gaskets for Hub & Spigot shall conform to the requirements of ASTM Standard C564" and ASTM C1563".
- Joints for pipe and fittings shall conform to the manufacturer's installation instructions and local code requirements.

, Most current edition

For more information, please contact:

[www.mcwanepumbingtechservices.com](http://www.mcwanepumbingtechservices.com)

[www.tylerpipe.com](http://www.tylerpipe.com) 800-527-8478

[www.abifoundry.com](http://www.abifoundry.com) 800-468-4766



PIPE & COUPLING